

11th May, 1998.

Dry-Treat (Australia) Pty Ltd PO Box 551 ST LEONARDS NSW 2065

Attention: Luke

Dear Sir,

Re: Resistance to Salt Attack Tests on Pavers.

We have now completed the above testing on pavers supplied by you to AS/NZS 4456.10. The results are shown below.

Test Method: Method A of AS/NZS 4456.10.

Date Tested: 3rd April, 1998 - 4th May, 1998.

Sample	Percentage Mass Loss After 15th Cycle (Ave)	Category
Sandstone 1 - Control	3.56	General purpose
Sandstone I – Treated DT40SK	0.00	Exposure
Sandstone 1 – Treated STAIN-PROOF	0.00	Exposure
Sandstone 2 - Control	3.45	General purpose
Sandstone 2 – Treated STAIN-PROOF	0.00	Exposure

Note: Sandstone 1 and Sandstone 2 - Damage: Rounding of Corners.

Please do not hesitate to contact us should you require any further assistance.

Yours sincerely,

By Cockle
Bronwen Cockle
Laboratory Manager