

EzeBond MS



Timber Flooring Adhesive

RE: EzeBond MS Timber Flooring Adhesive – Low VOC Conformance

To whom this may concern,

This is to confirm the volatile organic compound (VOC) content for EzeBond MS Timber Flooring Adhesive has been tested by a third-party testing lab. The VOC content determination testing was conducted in accordance with the required SCAQMD rule 1168.

SCAQMD rule 1168 states that USEPA Method 24 (Determination of Volatile Matter Content, Water Content, Density Volume Solids, and Weight Solids of Surface Coating) is the suitable determination of VOC content of adhesives and sealants. This reference method is widely accepted worldwide for the VOC content determination.

VOC Testing Method	Maximum Limit	Testing Result
USEPA Method 24 under SCAQMD Rule 1168	100 grams / Litre (timber flooring adhesive)	9.50 grams / Litre

Based on this testing outcome, EzeBond MS Timber Flooring Adhesive is considered to meet the low VOC wood flooring adhesive requirement.

For additional information, phone customer support on (03) 9561 9711.
Manufactured under licence for Woodcrete Pty Ltd:



4/16 Rosemary Crt
Mulgrave
VIC 3170
Tel: (03) 9561 9711