

VOC Content Test Certificate

Thursday October 6th, 2011

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills NSW 2147)

Sample Description: ARDEX K 301

Date Tested: October 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in
Various Materials as referenced by South Coast Air Quality Management District
(SCAQMD) Rule 1168

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	ARDEX K 301
One and two pack performance coatings for floors 140 grams per Liter as VOC content per material	6 grams per Liter as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV111002