

# VOC Content Test Certificate

Tuesday 25<sup>th</sup> October 2022

**Supplier** Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, SEVEN HILLS, NSW 2147, Australia).

**Sample Description** Ardex A48 22H007N

**Date Tested** October 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred to in accordance with the laboratory testing guidance from the Green Building Council of Australia.

## Test Results

Specification	
<b>Green Building Council of Australia</b>	<b>Ardex A48 22H007N</b>
<b>Green Star Design &amp; As Built V1.3-13.1.1B</b>	
<b>Green Star Interiors V1.3-12.1.1B</b>	
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>1 gram per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>

  
**Dr. Vyt Garnys**  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

  
**Dr. Tuan Duong**  
 PhD, BE (Chem. Eng.)  
 Senior Consultant

  
**Travis Hale**  
 BSc (Biotechnology)  
 Senior Consultant

**P22090047**