

# VOC Content Test Certificate

Wednesday, December 12, 2012

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills, NSW 2147)

Sample Description: Ardex K15 Microtec

Date Tested: November 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in  
Various Materials as referenced by South Coast Air Quality Management District  
(SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Ardex K15 Microtec</b>
Sub-Floor Adhesive  50 grams per Litre as VOC content per material	<b>5 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc  
Consultant

CV121116