

VOC Content Test Certificate

Thursday 05th September 2019

Supplier: Ardex Australia (7/20 Powers Road, Seven Hills, NSW, 2147, Australia).

Sample Description: ARDEX P9

Date Tested: September 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.2-13.1.1B Green Star Interiors V1.2-12.1.1B	ARDEX P9
Primers, Sealers, and Precoats: 65 grams per Litre	56 grams per Litre as VOC content per material
<i>We hereby certify that ARDEX P9 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V1908056