

VOC Content Test Certificate

Friday April 30th, 2010

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex A46 rapid hardening and rapid drying internal slump free mortar for external repairs

Date Tested: April 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	Ardex A46
Green Building Council of Australia	
Green Star Office Design V2 IEQ-13	
Green Star Office Interiors V1.1 IEQ-11	
Architectural Sealant 250 grams per Litre as VOC content material	5 grams per Litre as VOC content per coating
Specification	Ardex A46
Green Building Council of Australia	
Green Star Office Design V3 IEQ-13	
Architectural Sealant 250 grams per Litre as VOC content material	5 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F1004-34